



RADIUS (FT)	X (FT) **
15 *	6.32
20 *	5.52
25	5.13
30	4.90
35	4.75
40	4.64
45	4.56
∞	4.0

* DOUBLE ATTACHED RAMPS
NOT ALLOWED **ASSUME
RAMP LENGTH OF 6'

NOTES:

1. EXISTING CURB AND SIDEWALK TO BE SAWCUT AND REMOVED FOR INSTALLATION OF NEW RAMP.
2. RAMP MAY BE USED MID-BLOCK OR ON INTERSECTION RADII – WITH APPROVAL FROM THE CITY OF WASHOUGAL.
3. RAMP TO BE CENTERED IN CROSSWALK.
4. RAMP TO BE CONSTRUCTED SEPARATE AND ISOLATED BY CONSTRUCTION JOINTS.
5. IF A SINGLE DIAGONAL CURB RAMP IS PERMITTED, 48" CLEAR SPACE SHOULD BE PROVIDED MANEUVERING ROOM IN CROSSWALK.

CURB RAMP – TYPE 5

NTS