



NOTES:

1. FIRE HYDRANT INSTALLATIONS SHALL BE INSPECTED PRIOR TO BACKFILLING.
2. FIRE HYDRANTS SHALL BE PAINTED (BRUSH APPLIED) AFTER INSTALLATION W/STANDARD AWWA, GLOSS B, YELLOW

APPROVED HYDRANTS  
 MEULLER SUPER CENTURION  
 CLOW MEDALLION  
 KENNEDY GUARDIAN



STANDARD FIRE HYDRANT ASSEMBLY

DATE: December 2016

DETAIL NO.

W40